



## LOCAL AUTHORITY SPECIFIC REQUIREMENTS

### INTRODUCTION

This Section contains variations and additions to the Operational Works Guidelines, which are considered necessary for the effective application of the Guidelines in Cassowary Coast Regional Council and shall be treated as amendments to the Guidelines.

### CONTENTS

The following sections have varied or additional clauses

CLAUSE	CONTENTS	PAGE
	<b>DESIGN GUIDELINE - D1 ROAD GEOMETRY .....</b>	<b>1</b>
D 1.27	GENERAL.....	1
	<b>DESIGN GUIDELINE - D6 WATER RETICULATION .....</b>	<b>1</b>
D6.10	RETICULATION NETWORK .....	1
	<b>DESIGN GUIDELINE – D7 SEWERAGE SYSTEMS .....</b>	<b>1</b>
D7.16	PUMP STATIONS.....	1
	<b>CASSOWARY COAST REGIONAL COUNCIL STANDARD DRAWINGS .....</b>	<b>2</b>



## DESIGN GUIDELINE - D1 ROAD GEOMETRY

### D 1.27 GENERAL

#### ADDITIONAL CLAUSES

5. All roads constructed for rural residential subdivisions in Cassowary Coast Regional Council are required to have full depth pavement for the full width of the formation and be sealed for the full width of the pavement. Formation widths shall be in accordance with Table D1.4.

## DESIGN GUIDELINE - D6 WATER RETICULATION

### D6.10 RETICULATION NETWORK

#### ADDITIONAL CLAUSES

3. Where non-metallic pipe is laid a continuous stainless steel wire, 1.6mm (min) diameter, or detectable marking tape, shall be laid immediately above the pipe to assist in future location. This wire shall be wrapped once around all hydrants and sluice valves.
4. The minimum test pressure for all pipes shall be 1200 KPa and twenty-four (24) hours notice is to be given to the relevant Council Officer prior to testing. Council's minimum test pressure and inspection notification requirements are to be clearly noted on the approved Project Drawings / Specification.

## DESIGN GUIDELINE – D7 SEWERAGE SYSTEMS

### D7.16 PUMP STATIONS

#### ADDITIONAL CLAUSE

12. All pump stations must be fitted with telemetry system in accordance with Council's Specification for Telemetry Systems. Council should be contacted to obtain a copy of their Technical Specification and requirements for Telemetry Systems.

**CASSOWARY COAST REGIONAL COUNCIL STANDARD DRAWINGS**

1. The following additional Standard Drawings shall be deemed to be applicable for those works that shall ultimately become Cassowary Coast Regional Council's responsibility for ongoing maintenance:

<b>Drawing No.</b>	<b>Revision</b>	<b>Title</b>
09002	r1	Standard Above Ground Water Meter Plan & Elevation
09039	r0	Standard Below Ground Water Meter Plan & Elevation
09040	r0	Standard Water Details Water Services to Rural & Residential Allotments
09041	0	Standard Detail Rollover Kerb & Channel Elevation
09042	0	Public Utilities Allocation in Footpaths Residential & Rural Residential