



## NOTES

1. Entry grates are required on all pipes and R.C.B.C. entering an underground drainage system. Grates are not required on culverts under roadways.
2. All steel work shall be hot dipped galvanised to AS 1560 after fabrication.
3. All welds shall conform to AS 1554 and be 6mm C.F.W. unless noted otherwise.
4. Side bar protection to be provided only to headwalls with no wingwalls.
5. All dimensions are in millimetres.

[illegible]