



1. ALL CONNECTIONS ARE TO BE UNDERTAKEN BY COUNCIL.
2. STANDARD DOMESTIC SERVICE IS 20mm.
3. NORMAL LOCATION OF WATER SERVICE TO BE ON OPPOSITE BOUNDARY TO ELECTRICITY SUPPLY.
4. NORMAL WATER SERVICE LOCATION TO BE 200mm INSIDE THE FRONT BOUNDARY AND OFFSET 300mm FROM THE SIDE BOUNDARY.
5. NORMAL POSITION OF CONDUITS UNDER FOOTPATHS (WHERE REQUIRED) SHALL BE A MINIMUM OF 80mm DIAMETER PVC CLASS 6 WITH 300mm COVER, 300mm OFFSET FROM THE SIDE BOUNDARY AND EXTEND 300mm PAST THE EDGE OF THE FOOTPATH.
6. THE POSITION OF CONDUITS UNDER FOOTPATHS SHALL BE CLEARLY MARKED BY THE CASTING OF NON-FERROUS CUPHEAD BOLT INTO THE PROPERTY SIDE OF THE FOOTPATH WHILE THE CONCRETE IS WET.

[illegible]