

**03/08/2015**

**Commentary against S2.04 – Asphaltic Concrete Surfacing Item 1.**

1. Identifies requirements as specified in the “Asphalt Specification for Subdivision Pavements” published by the Australian Asphalt Pavement Association (Queensland Branch)

It has come to our attention that this specification is no longer available. Reference should be made to TMR’s MRTS30 for all Council asphalt works (30mm and 50mm).

Reference should also be made to Austroads so there is no confusion about min asphalt depth when using DG10.