

SLUICE VALVE



SLUICE VALVE

(WITH EXTENSION SPINDLE)

NOTES

1. Precast surrounds to be 100mm minimum width and shall be painted white.
2. Gap between precast surround and cover box shall be mortar filled after final levelling.
3. Valves shall be installed so the valve spindle is aligned with centre of cover opening and cover is level in surrounding ground.
4. All Ø50 gate valves shall be fitted with bronze tee handles.
5. Valves to be coated with thermosetting epoxy powder to AS 3952 and AS 2638. All bolts stainless steel grade 316 to AS 2837.
6. All galvanising to AS 1650.
7. Refer to Standard drawing S2010 for Kerb/Road Marker Installation
8. All dimensions are in millimetres.



SPINDLE FIXING DETAIL

REVISIONS	DATE
F REMOVAL OF Ø50 VALVE SLEAVE	17/10/19
E REMOVAL OF LOCATION WIRES	21/02/11
D INCLUSION OF LOCATION WIRES	29/09/08
C MINOR AMENDMENTS	25/08/05
B COUNCIL SPECIFIC	23/11/04

DISCLAIMER

The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, or consequentiol damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.

TRC
TABLELANDS REGIONAL COUNCIL
45 Mabel Street, Atherton QLD 4883
PO Box 573, Atherton QLD 4883
P: 07 4043 4200 F: 07 4091 4300
Email: info@trc.qld.gov.au
Web: www.trc.qld.gov.au

VALVE BOX INSTALLATION

Standard Drawing
S2000
B C D E F