

MASONARY ANCHORS


CORED HOLE

NOTES

1. Refer project drawings for fence and footing types.
2. Type 2 handrail shall be used in all areas where the ground level is below the ARI 50 year storm inundation line and where debris collection is likely.
3. Construction of posts & rails shall be done using standard coupling connections only. (no welds).
4. Chairwire mesh shall be H.D. galvanised 2.6mm thick x 50 mesh opening.
5. Concrete N25 in accordance with AS1379 & AS3600.
6. All dimensions in millimeters.

DISCLAIMER

The authors and sponsoring organizations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, or consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.



HANDRAIL / TUBULAR STEEL FENCE

Standard
Drawing
S1025

A ORIGINAL ISSUE	12/3/04
REVISIONS	DATE

[illegible]