



ELECTRICAL SWITCHBOARD LOCATION TO BE CONFIRMED BY CRC - MUST COMPLY WITH AS3000.



- MIN CLEARANCE
- *FLANGE TO WALL = 200mm
 - *BETWEEN PUMP PLINTHS AND WALL = 800mm
 - *BETWEEN PUMP PLINTHS AND BUILDING = 600mm

REVISIONS	DATE
A INITIAL ISSUE	08/11/17

DISCLAIMER

The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, or consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.



WATER LIFT PUMP STATION
LAYOUT PLAN

Standard
Drawing
S2040

A			
---	--	--	--