


ELEVATION



BARRIER FENCE

NOTES

1. Posts to be 125mm x 125mm x 1500mm with a 64mm hole.
2. Provide 1200mm walk through gaps.
3. Galvanised pipe 50mm (60.3OD) by max 6500mm in length with galvanised caps (site specific).
4. In sloping terrain posts shall remain vertical & rails shall be parallel with ground surface.
5. Alternate post and rail fixing details to be approved by Council.
6. All dimensions are in millimetres.
7. Recycled plastic materials are the preferred alternative to treated timber.
8. Alternative materials to be approved by Council prior to construction.
9. Proprietary removable Galvanised Steel bollards with locking mechanism (powder coated or painted safety yellow with reflective tape) for park access to be approved by Local Authority and installed as per manufacturers specifications.
10. For bollards refer FNQROC standard drawing S4300.
11. Post and rail should be setback 100mm from reserve property boundary, avoiding the verge where possible.

DISCLAIMER The Cairns Regional Council shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, or consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.



STANDARD DRAWING
LANDSCAPING GUIDELINES
POST AND RAIL

DRAWING NUMBER	
S4320-CRC	
REV	A

No.	Description	Date
A	ORIGINAL ISSUE	27/08/20
Approved for use GM City Works & Services		