



CONNECTION DETAIL

CASSOWARY COAST REGIONAL COUNCIL
STANDARD COPPERSETTER
(AVAILABLE HITC AUST PTY LTD
PH 0438778295
FAX 33485220
PART NO FOR ORDERING 19:103T)
OR SIMILAR

NOTES

1. ALL WORK TO CONFORM TO AS/NZS 3500 "PLUMBING AND DRAINAGE", AS 4809 "COPPER TUBE AND FITTINGS" - INSTALLATION AND COMMISSIONING" AND AS 2033 "INSTALLATION OF POLYETHYLENE PIPE SYSTEMS".
2. WATER METER ASSEMBLY TO HAVE A MINIMUM OF 200 mm CLEARANCE INSIDE PROPERTY BOUNDARY
3. WATER METER TO BE MARKED WITH A BLUE STEEL MARKER POST WITH WHITE VINYL WORDS "WATER METER" (DURAPOST FSM 2210 OR SIMILAR) & SURROUNDING VEGETATION TO BE MAINTAINED REGULARLY
4. WHERE ABOVE GROUND WATER METER IS NOT APPLICABLE, REFER TO DRG 05012 - BELOW GROUND WATER METER



DIMENSIONS IN MILLIMETRES

Issue	Amendments	Initial	Date	References	Cassowary Coast Regional Council Logo	Scale	1:5 @ A3	Date	NOVEMBER 2008	Doc N°	09002
1	CHANGED PVC PICKET TO STEEL MARKER POST		24/6/09	DRG 05012 BELOW GROUND WATER METER		Drawn	A.G.	Return	AHDD	STANDARD ABOVE GROUND WATER METER PLAN & ELEVATION	
					ENGINEERING SERVICES DEPT. Ph (07) 4030 2272 CLARE STREET, INNISFAIL QLD. Fax (07) 40617685	Designed	R.J.	Approved		Vol N°	v1/1
						Checked	R.J.			Issue N°	r1