



SLUICE VALVE




Ø50 VALVE SLEEVE


50mm valve on ring mains must be installed as per sluice valve design (plastic surround).



**SLUICE VALVE
(WITH EXTENSION SPINDLE)**



SPINDLE FIXING DETAIL



NOTES

1. Precast surrounds to be 100mm minimum width and shall be painted white.
2. Gap between precast surround and cover box shall be mortar filled after final leveling.
3. Valves shall be installed so the valve spindle is aligned with centre of cover opening and cover is level in surrounding ground.
4. All Ø50 gate valves shall be fitted with bronze tee handles.
5. Valves to be coated with thermosetting epoxy powder to AS 3952 and AS 2638. All bolts stainless steel grade 316 to AS 2837.
6. All galvanising to AS 1650.
7. All dimensions are in millimetres.

REVISIONS	DATE
	12/3/04

DISCLAIMER
The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, or consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.

Mareeba
SHIRE COUNCIL
MAREEBA SHIRE COUNCIL
11-15 Kowa Street, Mareeba QLD 4880
PO Box 154, Mareeba QLD 4880
P: 1300 308 461 F: 07 4092 3323
Email: info@msc.qld.gov.au
Web: www.msc.qld.gov.au

VALVE BOX INSTALLATION

Standard Drawing
S2000

A				
---	--	--	--	--