



FIRE HYDRANT

NOTES

1. Precast surrounds to be 100mm minimum width and shall be painted yellow.
2. Long side of cover box opening shall be aligned with water main to locate recesses with hydrant bolts.
3. Gap between precast surround and cover box shall be mortar filled after final levelling.
4. Depth of hydrant shall be 75mm from top of box to top of lug where possible, with an absolute maximum depth of 125.
5. All hydrants shall be installed with dust covers.
6. Hydrant tees and risers to be DICL.
7. Hydrants to be coated with thermosetting epoxy powder to AS 3952 and AS 2638. All bolts stainless steel grade 316 to AS 2837.
8. Refer to Standard Drawing S2010 for Kerb/Road Marker Installation.
9. All dimensions are in millimeters

E	REMOVAL OF LOCATION WIRES	21/02/11
D	INCLUSION OF LOCATION WIRES	29/09/08
C	MINOR AMENDMENTS	25/08/05
B	COUNCIL SPECIFIC	23/11/04
A	ORIGINAL ISSUE	12/03/04
	REVISIONS	DATE

DISCLAIMER

The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, or consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.



45 Mabel Street, Atherton QLD 4883
 PO Box 573, Atherton QLD 4883
 P: 07 4043 4200 F: 07 4091 4300
 Email: info@trc.qld.gov.au
 Web: www.trc.qld.gov.au

HYDRANT BOX INSTALLATION

Standard
 Drawing
S2005

A	B	C	D	E
---	---	---	---	---