



STOP VALVE

Characters 10mm thick. SCOUR VALVE

AIR RELEASE

FIRE HYDRANT

Rotate plate to suit location of hydrant.
 Arrowhead to location of hydrant.
 . Upwards - Behind marker
 . Downwards - In front of marker

MARKER POST

NOTES

1. Marker plates shall be constructed 1.6mm aluminium sheet.
2. Marker plates shall be fixed to post with stainless steel wood screws (4 per plate).
3. Letters and figures for all valve plates shall be painted in black enamel with backgrounds painted with an enamel paint as follows :
 - Water - White.
 - Sewerage - Red.
4. Letters and figures for all hydrant plates shall be painted in black enamel with a reflective yellow background.
5. Upper 900mm of post to be painted with 3 coats of an approved white oil based paint. Hydrant posts to have a 200mm wide red band painted at approximately the mid section.
6. All posts shall be set in concrete with a minimum surround of 75mm. Concrete to be N32 minimum in accordance with AS 1379 and AS 3600.
7. Alternate proprietary recycled plastic posts may be used subject to Council approval.
8. All dimensions are in millimetres.

REVISIONS		DATE
C	MINOR AMENDMENT TO NOTES	05/12/23
B	MINOR AMENDMENTS	25/10/17
A	ORIGINAL ISSUE	12/03/04

DISCLAIMER

The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, or consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.



MARKER POSTS

Standard Drawing S2012			
A	B	C	